

CERTIFICATE of Conformity



Certificate No.: MK 69250996 0001

Test Report No.: 28229216 001

Certificate Holder: Thinh Phat Real Estate-Cables Joint Stock Company
No:144 A, Ho Hoc Lam street, An Lac ward, Binh Tan district
Ho Chi Minh City
Viet Nam

Manufacturer: Thinh Phat Real Estate-Cables Joint Stock Company
No:144 A, Ho Hoc Lam street, An Lac ward, Binh Tan district
Ho Chi Minh City
Viet Nam

Product: FR-PVC insulated, fire resistant cables of rated voltage 0,6/1kV

Identification: Type designation: Cu/Mica/Fr-PVC single core
1,5mm² to 10mm²
Trade mark: THIPHA Cable
See detailed information in Annex.

The cable was tested by using three lengths of the cable laid side by side and with a slight twist along its length to ensure that each length was in good contact with the next cable.

This Certificate verifies only the conformity to part D.2, D.3, D.4 of the below listed standard.

Tested according to: BS 6387:1994
Category C
Category W
Category Z

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2015.11.02



Nominal cross section area	Conductor		Insulation thickness	Overall diameter (approx.)	Max. Conductor DC resistance	Weight (approx.)
	No/Dia	Dia. Over conductor (approx)				
mm ²	No/mm	mm	mm	mm	Ω/km	kg/km
1x1,5	7/0,52	1,56	0,8	3,8	12,1	30
1x2,5	7/0,67	2,01	0,8	4,2	7,41	40
1x4	7/0,85	2,55	1,0	5,1	4,61	62
1x6	7/1,04	3,12	1,0	5,7	3,08	83
1x10	7/C.C	3,75	1,0	6,3	1,83	124

TÜVRheinland

Date of issue:

Budapest, 2015.11.02.



Certification Body

1. *[Signature]*

Goltan Rostas

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu